



FINANCE OFFICE

7 North Dixie Highway · Lake Worth, Florida 33460 · Phone: 561-586-1674

Addendum No. 1
IFB 15-104

INSTRUMENT TRANSFORMER TESTING

Each recipient of this Addendum No. 1 to the Invitation for Bid (IFB) who responds to the IFB acknowledges all of the provisions set forth in the IFB and agrees to be bound by the terms thereof. This addendum shall modify, clarify, change or add information and clarification and become part of the above referenced IFB.

CLARIFICATION:

1. Under the Scope of Services Section #1; there is mention of “replacing meter enclosure, current transformers, wires and conduit as needed”. This portion of the project presents a variable that makes it relatively impossible to set a fixed price per meter when there is no means of determining how many of the 600 locations might end up requiring this attention. In light of the requirement to utilize the specific bid forms provided, would it not be advisable to add a line item for these particular efforts?
A: The cost for these additions will be covered on page 2 of Addendum No. 1
2. Section 1: Change meter as needed (the City will provide the replacement meter) at no load or light load sites- What is required for this condition?
A: If the service needs to be disconnected, the city will have that done.
3. Section 1: Replace meter enclosure, current transformers, wires and conduit as needed (all the above will provided by the City of Lake Worth)-Is this work expected to be done as a part of the testing cost?
A: Please list the price for each additional item listed on page 2 of Addendum No. 1

INSTRUMENT TRANSFORMER TESTING

IFB# 15-104

SCHEDULE OF BID ITEMS– REVISED FOR ADDENDUM #1

In accordance with the scope of work and specifications noted in this IFB document, following are the fixed prices to provide all required services.

PRICE PER **TEST SITE**: \$ _____

Estimated Start Date (should be after April 1, 2015): _____

Estimated Completion Date: _____

Replace 3 Phase Meter Enclosure (Parts Supplied by City) \$ _____

Replace Electric meter if needed (Parts Supplied by City) \$ _____

Replace bad Current Transformer(s) (Parts Supplied by City) \$ _____

Replace bad wiring as needed (Parts Supplied by City) \$ _____

Replace bad conduit as needed (Parts Supplied by City) \$ _____

Name of Contractor: _____

Address: _____ St _____ Zip _____

Phone: (____) _____ Email: _____

Print Name: _____ Title: _____

SIGNATURE: _____ **Date:** _____

Proposers must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the IFB documents and therefore must be executed and submitted with your proposal.

Issued By: City of Lake Worth
Finance Office
January 20, 2015

Signed By: 
Hirut Darge
Purchasing Agent

PROPOSER/Company

Name: _____

Signed By: _____

Print Name: _____

Title: _____

Date: _____