



DEPARTMENT OF FINANCE

7 North Dixie Highway · Lake Worth, Florida 33460 · Phone: 561-586-1674

**Addendum No. 1
IFB 15-107**

7th Avenue South Roadway, Stormwater & Water Main Improvements

TO ALL BIDDERS AND OTHERS CONCERNED:

Contractors submitting proposals for the above referenced project shall take note of the clarification to the Contract Drawings and Specifications that shall become a part of the contract documents.

THE DUE DATE FOR BID DOCUMENTS IS: Wednesday, June 24, 2015 by 2:00 P.M., at the City of Lake Worth Procurement Office, 7 North Dixie Highway, 2nd Floor, Lake Worth, FL 33460.

Note: Bidder must acknowledge Receipt of Addendum on Bid Proposal - Page BP-2 of the Contract Documents.

Questions & Answers:

Q1: What is the project cost estimate?

A1: The estimated cost for the project is \$675,000.

Q2: Who pays for the testing?

A2: The contractor is responsible for paying all the costs and scheduling all work associated with testing.

Q3: Any specific MOT plans?

A3: The contractor is required to submit a certified MOT plan for review and approval by the City. The contractor may close the intersections provided a sufficient detour route is proposed and accepted by the City.

Q4: Working Hours? Weekends?

A4: Work hours are from 8am to 6pm, Monday through Friday per City ordinance, unless otherwise authorized by the City. On Saturday, from 8am to 6pm. No work on Sunday & Holiday, unless a waiver is authorized by Public Services with at least a 48 hours advanced notice.

The City shall assure that neither the prime contractor nor any subcontractor shall be allowed to perform one hundred percent (100%) of their work on this project on nights, weekends, or County recognized holidays, and shall assure that the prime contractor and all subcontractors shall, at a minimum, perform work on this project for the duration of one regular working day. The Municipality may request DES for a waiver to the above requirement should the nature of the project so necessitate, and in such instance, DES may, at its discretion, grant the Municipality such waiver.

Q5: Permits required? Permit Fee waived?

A5: Permit Fees are to be reimbursed by the Permit Fee Allowance. Dewatering permit, NPDES permit may be required.

Q6: SFWMD may require an engineer to certify (sign/seal) a dewatering plan; will Mathews Consulting perform this task?

A6: The City or Mathews Consulting will not sign/seal a contractors dewatering plan. The contractor will be responsible to have the plan signed/sealed.

Q7: Is this pre-bid meeting mandatory?

A7: No, the pre-bid meeting is non-mandatory.

Clarifications

1. When questions raised are deemed appropriate by the Engineer, in its sole discretion, they shall be answered in the form of Addenda. No oral answers to questions will be given. All Addenda so issued shall become a part of the Contract Documents, and must be acknowledged. To receive consideration, such questions shall be submitted in writing, by US mail, fax or email to: [Ms. Hirut Darge, Finance Department, City of Lake Worth, 7 N. Dixie Hwy., Lake Worth, FL 33460, E-mail: hdarge@lakeworth.org, Phone \(561\) 586-1651, Fax \(561\) 586-1750](mailto:hdarge@lakeworth.org) (refer to page 12 of 38).

2. Pre-construction meeting will be held immediately upon execution of the contract by the City. City anticipates issuing the Notice of Award within 1 week of bid opening and have the contract approved at the City Commission meeting in July or August. City Commission meetings occur on the first and third Tuesday of every month. The contract also needs to be approved by the Palm Beach County's Department of Economic Sustainability. The pre-construction meeting is projected to be early September, 2015.

3. The Contractor must provide door hangers a few days prior to beginning construction with a block by block alert, notification must include 2 blocks north and south of the work at minimum.

4. Note that there are some old water mains in the project area that the Contractor needs to be careful around. As a result, vibratory compaction rollers are not permitted. The City will assist Contractor with location of the existing Lake Worth utilities. Only City staff are permitted to operate the existing valves.

Proposers must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the IFB documents and therefore must be executed and submitted with you proposal.

Issued By: City of Lake Worth
Finance Office
June 12, 2015

Signed By: 
Hirut Darge
Purchasing Agent

PROPOSER/Company

Company Name: _____

Signed By: _____ Print Name: _____

Title: _____ Date: _____

Attachments: Pre-Bid Conference Sign-In sheet

Cc: Attendees
Felipe Lofaso – Lake Worth
Dave Mathews - MC
MC File #1738