



FINANCE OFFICE

7 North Dixie Highway · Lake Worth, Florida 33460 · Phone: 561-586-1674

**Addendum No. 1
RFP 15-108**

**REPLACEMENT OF TWO VARIABLE FREQUENCY DRIVES AT THE
MASTER PUMP STATION**

Each recipient of this Addendum No. 1 to the Invitation for Bid (IFB) who responds to the IFB acknowledges all of the provisions set forth in the IFB and agrees to be bound by the terms thereof. This addendum shall modify, clarify, change or add information and clarification and become part of the above referenced IFB.

CLARIFICATION:

- 1) Can both VFD's that are being replaced be removed and replaced at the same time? If so, for how long can they both be offline? Or will 1 VFD need to be online before the other can be removed?
A: The VFD for pump 101 must be installed and online first. You should not have both 101 and 102 out of service at the same time.
- 2) The VFD that was already removed is sitting in the electrical room. Please advise what the contractor is required to do with the 2 VFD's that are to be removed, per this bid?
A: Yes, it is required that both VFD's be removed as part of this project.
- 3) Which VFD units are getting replaced?
A: Units #101 and #102.

Proposers must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the IFB documents and therefore must be executed and submitted with your proposal.

Issued By: City of Lake Worth
Finance Office
June 3, 2015

Signed By: *Hirut Darge*
Hirut Darge
Purchasing Agent

PROPOSER/Company

Name: _____

Signed By: _____

Print Name: _____

Title: _____

Date: _____