

ENGINEER'S PROJECT NO. B4015 PROJECT: Potable Well No. 12 Reconstruction
for City of Lake Worth

DATE: December 10, 2014

ADDENDUM NO. 1

TO: ALL PROSPECTIVE BIDDERS

Pursuant to the Invitation to Bid on this Project, you are instructed to make the following modifications to the Project Contract Documents, which modifications shall constitute a portion of the Contract Documents and be an integral part of the Project:

PROJECT MANUAL

- (1) Section 11213, Revise paragraph 1.05.E to read "Total pump head at design capacity – 106 feet".
- (2) Section 11213, paragraph 2.02 Materials, A.6., Allow alternate material for the impellers and bowl assembly to be 316 stainless steel

/s/ MOCK, ROOS ASSOCIATES, INC.

END OF ADDENDUM NO. 1