



Financial Services

7 North Dixie Highway
Lake Worth, FL 33460

561.586.1651

Addendum #1

IFB 16-123

LAKE WORTH SWIMMING POOL BOILER REPLACEMENT

Each recipient of this Addendum No. 1 to the Invitation for Bid (IFB) who responds to the IFB acknowledges all of the provisions set forth in the IFB and agrees to be bound by the terms thereof. This addendum shall modify, clarify, change or add information and clarification and become part of the above referenced IFB.

CLARIFICATION:

1. In section #2 it says that contractor must have a valid HVAC license and a Valid Plumbing license. We have A Mechanical license that according to the Florida Statues 489.105 section (I) lets us perform boiler installations. It is my interpretation that as long as we disconnect/ reconnect the existing pool water lines we are within our License qualifications. My question is can we definitely bid this project?
A) Yes
2. Do you want the boilers set directly on the slab or do you want them elevated on an equipment pad?
A) Set the boilers on the pad like the existing ones
3. The like for like unit doesn't come with a digital thermostat. It isn't recommended to use one from the factory. Please specify the aftermarket controller you would like to use.
A) No temperature control, existing ones need to be installed on the new boilers
4. Page 4, Section 1-Scope of Work added #10 must come with Temperature Control.
A) Existing temperature controls will be re-installed on new Boilers



Proposers must acknowledge receipt of this Addendum No. 1 in the space provided below. This Addendum forms an integral part of the RFP documents and therefore must be executed and submitted with you proposal.

Issued By: Financial Services
September 12, 2016

Signed By: *Hirut Darge*
Hirut Darge, Purchasing Agent

PROPOSER/Company

Name: _____

Signed By: _____ Print Name: _____

Title: _____ Date: _____