



NOTE: INSTALLATION OF PAVER BRICKS SHALL BE IN CONFORMANCE WITH MANUFACTURER'S INSTALLATION CRITERIA. PAVER BRICK THICKNESS SHALL BE MINIMUM 2-3/8 INCHES. PAVER BRICK SHALL BE COLORED THROUGH THE FULL DEPTH OF THE PAVER AND NOT JUST THE SURFACE. THE SAND BEDDING COURSE SHALL BE WELL GRADED, CLEAN, WASHED LIMESTONE SCREENINGS WITH 100% PASSING A 3/8" SIEVE SIZE AND A MAXIMUM 3% PASSING A No. 200 SIEVE SIZE. DO NOT USE MASON SAND. ALL EDGES OF THE PAVER BRICK SHALL BE RESTRAINED BY CONCRETE HEADER CURB OR VALLEY GUTTER. CITY TO APPROVE SIDEWALK PAVER MANUFACTURER, TYPE, COLOR, AND SIZE. SUBMIT THREE (3) SAMPLE PAVERS FOR APPROVAL.

PAVER BRICK DETAIL

N.T.S.

